



Hopatcong Borough Schools

P.O. Box 1029 • Hopatcong, New Jersey 07843 • (973) 770-8840 • FAX (973) 398-2590
Matthew Geary, Facilities Supervisor

June 8th, 2022

Hopatcong Borough Schools
Durban Avenue School
616 Durban Avenue
Hopatcong, NJ 07843

Dear Durban Avenue School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Hopatcong Borough Schools tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Durban Avenue School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Hopatcong Borough Schools. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 13 samples taken, all but 1 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlet(s) that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Hopatcong Borough Schools has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
First Floor Kitchen Dish-Wash Hose	76.0	Outlet immediately taken out of service.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at <https://www.hopatcongschools.org/p/facilities/>. For more information about water quality in our schools, contact Matthew Geary at the Facilities Department at 973-770-8840 or email at mgeary@hopatcongschools.org.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,
Matthew Geary
Facilities Supervisor

Chain of Custody

- Environmental Lead -

Contact Information	
Client Company: Garden State Environmental, Inc.	Project Number: 8402
Office Address: 555 South Broad Street	Project Name: Durham ES, Hopatcong
City, State, Zip: Glen Rock, NJ 07452	Primary Contact: Christian Valdes
Fax Number: 201-652-0612	Office Phone: 201-652-1119
Email Address: labreports@gseconsultants.com	Cell Phone: _____

iATL is accredited by the National Lead Laboratory Accreditation Program (NLLAP) to perform analytical testing of environmental samples for lead (Pb). The accreditation is through AIHA-LAP, LLC and several other nationally recognized state programs.

Matrix/Method:

- Paint by AAS: ASTM D3335-85a, 2009
- Wipe/Dust by AAS: SW 846: 3050B: 700B, 2010
- Air by AAS: NIOSH 7082, 1994
- Soil by AAS: EPA SW 846 (Soil)
- Water by AAS-GF: ASTM D3559-03D, US EPA 200.9
- Other Metals (Cd, Zn, Cr) by AAS
- Toxicity Characteristic Leaching Procedure (TCLP) by AAS: US EPA 1311
- Other _____

Special Instructions:

Turnaround Time

Preliminary Results Requested Date: _____

Specific date / time

Verbal Email Fax

10 Day 5 Day 3 Day 2 Day 1 Day* 12 Hour** 6 Hour** RUSH**

* End of next business day unless otherwise specified. ** Matrix Dependent. ***Please notify the lab before shipping***

RECEIVED

Chain of Custody

Relinquished (Name/Organization):	Christian Valdes	Date:	4/28/22	Time:	1:45 pm
Received (Name / iATL):	MAY - 4 2022	Date:		Time:	
Sample Login (Name / iATL):		Date:		Time:	
Analysis(Name(s) / iATL):	crstilla	Date:		Time:	
QA/QC Review (Name / iATL):		Date:		Time:	
Archived / Released:		Date:		Time:	
	iATL By	Date:		Time:	



Sample Log

-Environmental Lead-

Client: _____ Project: Durban Ave Elementary Hopatcong

Sampling Date/Time: 4/23/22 2:25 pm

Client Sample #	iATL #	Location/ Description	Flow Rate	Start End	Sampling time (min)	Area (ft ²) Volume (L)	Results ()
HD-1-WC-02A	7421376	Hall by C-1	-	2:25	initial	-	
HD-1-BF-02A	7421377	Hall by C-1	-	2:26	initial	-	
HD-1-S-04A	7421378	Nurse Room	-	2:27	initial	-	
HD-1-WC-03A	7421379	Hall Outside Nurse	-	2:28	initial	-	
HD-1-BF-03A	7421380	Hall Outside Nurse	-	2:29	initial	-	
HD-1-H-02A	7421381	Kitchen Comp Horse	-	2:31	initial	-	
HD-1-S-03A	7421382	Kitchen Comp Left	-	2:32	initial	-	
HD-1-H-01A	7421383	Dishwash Horse	-	2:33	initial	-	
HD-1-WC-01A	7421384 7421385	Hall by D-9	-	2:34	initial	-	
HD-1-BF-01A		Hall by D-9	-	2:36	initial	-	
HD-1-S-01A	7421386	Faculty Room	-	2:38	initial	-	
HD-4- 23-FBA	7421387	-	-	-	-	-	
HD-1-S-02A	7421388	Kitchen Comp Right	-	2:33	initial	-	
* HD-1-S-05A	7421389				Acidified	MS	
	extra	sample rec'd			5/7/22	100	

* = Insufficient Sample Provided to Perform QC Reanalysis (< 200µg)

** = Insufficient Sample Provided to Analyze (< 50mg) *** = Matrix / Substrate Interference Possible

FB = Method Requires the submittal of blanks). ML = Multi Layered Sample. May result in inconsistent results.

These preliminary results are issued by iATL to expedite procedures by clients based upon the above data. iATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificate of Analysis will follow these preliminary results. The signed COA is to be considered the official results. All EPA, HUD, and NJDEP conditions apply.

CERTIFICATE OF ANALYSIS

Client: Garden State Environmental, Inc.
555 S Broad St. Ste. K
Glen Rock NJ 07452

Client: GAR373

Report Date: 5/11/2022
Report No.: 660317 - Lead Water
Project: Durban ES, Hopatcong
Project No.: 8402

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7421376 Location: Hall By C-1 Result(ppb): <1.00
Client No.: HD-1-WC-02A * Sample acidified to pH <2.

Lab No.: 7421377 Location: Hall By C-1 Result(ppb): <1.00
Client No.: HD-1-BF-02A * Sample acidified to pH <2.

Lab No.: 7421378 Location: Nurse Room Result(ppb): 9.00
Client No.: HD-1-S-04A * Sample acidified to pH <2.

Lab No.: 7421379 Location: Hall Outside Nurse Result(ppb): <1.00
Client No.: HD-1-WC-03A * Sample acidified to pH <2.

Lab No.: 7421380 Location: Hall Outside Nurse Result(ppb): <1.00
Client No.: HD-1-BF-03A * Sample acidified to pH <2.

Lab No.: 7421381 Location: Kitchen Comp Hose Result(ppb): <1.00
Client No.: HD-1-H-02A * Sample acidified to pH <2.


Lab No.: 7421382 Location: Kitchen Comp Left Result(ppb): 5.60
Client No.: HD-1-S-03A * Sample acidified to pH <2.


Lab No.: 7421383 Location: Dishwash Hose Result(ppb): 76.0
Client No.: HD-1-H-01A * Sample acidified to pH <2.

Lab No.: 7421384 Location: Hall By D-9 Result(ppb): <1.00
Client No.: HD-1-WC-01A * Sample acidified to pH <2.

Lab No.: 7421385 Location: Hall By D-9 Result(ppb): <1.00
Client No.: HD-1-BF-01A * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2022
Date Analyzed: 05/11/2022
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Garden State Environmental, Inc.
555 S Broad St. Ste. K
Glen Rock NJ 07452

Report Date: 5/11/2022
Report No.: 660317 - Lead Water
Project: Durban ES, Hopatcong
Project No.: 8402

Client: GAR373

LEAD WATER SAMPLE ANALYSIS SUMMARY


Lab No.: 7421386 Location: Faculty Room Result(ppb): 7.20
Client No.: HD-1-S-01A * Sample acidified to pH <2.


Lab No.: 7421387 Location: Result(ppb): <1.00
Client No.: HD-4-23-FBA * Sample acidified to pH <2.

Lab No.: 7421388 Location: Kitchen Comp Right Result(ppb): <1.00
Client No.: HD-1-S-02A * Sample acidified to pH <2.

Lab No.: 7421389 Location: Additional Sample Received Result(ppb): <1.00
Client No.: HD-1-S-05A * Sample acidified to pH <2.

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 5/4/2022
Date Analyzed: 05/11/2022
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Garden State Environmental, Inc.
555 S Broad St. Ste. K
Glen Rock NJ 07452

Client: GAR373

Report Date: 5/11/2022
Report No.: 660317 - Lead Water
Project: Durban ES, Hopatcong
Project No.: 8402

Appendix to Analytical Report:

Customer Contact: Send ALL Lab Reports
Analysis: AAS-GF - ASTM D3559-08D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: ?wchampion@iatl.com
iATL Account Representative: Kelly Klippel
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-08D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B

- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB

CERTIFICATE OF ANALYSIS

Client: Garden State Environmental, Inc.
555 S Broad St. Ste. K
Glen Rock NJ 07452

Report Date: 5/11/2022
Report No.: 660317 - Lead Water
Project: Durban ES, Hopatcong
Project No.: 8402

Client: GAR373

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.