



7469 Whitepine Rd
 North Chesterfield, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 25-04-04305

Client: LEW Corp
 181 US Hwy 46
 Mine Hill, NJ 07803

Received Date: 04/23/2025
 Reported Date: 04/29/2025
 Sampled By: Marvin Ayumbi
 Tech Certification #:

Project/Test Address: 2735; Admin Building; 2 Windsor Ave; Hopatcong, NJ 07843

Client Number:
 201327

Laboratory Results

Fax Number:
 Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
25-04-04305-001	1	04/12/2025	AB-BB-KIT	5.21	04/26/2025	
25-04-04305-002	2	04/12/2025	QAQC-BLANK	<1.00	04/26/2025	

Method: EPA 200.8
 Analyst: Nicole Holloway
 Accreditation #: NJ VA008

Reviewed By Authorized Signatory: *Melissa Kanode*

Melissa Kanode
 QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart® Lead Chain-of-Custody Form

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907 www.leadlab.com

25-04-04305



Due Date: 04/30/2025 (Wednesday) AE

Client Name: LEW Environmental Services, LLC Account #: 201327

Address: 181 US Hwy 46

City/State/Zip: Mine Hill, NJ 07803 Phone: 908-654-8068

Email Address: labresults@lewenvironmental.com

Project Name/ Number: Admin Building / 2735

Collection Address: 2 Windsor Ave City/State/Zip: Hopatcong NJ 07843

Approx. Age Of Property: Collected By: Marvin Ayumbi

Water Source: (Check One) Public X or Well Well Tag # (if applicable):

Turn-Around Time X 5 Days 3 Days 2 Days 1 Day

Table with 6 columns: No., Client Sample ID, Collection Location (Ex: Kitchen Sink), Collection Date, Collection Time, and Analyte (Pb, Cu). Rows 1-2 contain handwritten data: 1 AB-BB-KIT 04/12/25 AM/PM X; 2 QAQC-Blank 04/12/25 AM/PM X.

Released by: Marvin Ayumbi Signature: [Signature] Date/Time: 04/12/25
Received by: KTHARRIS Signature: [Signature] Date/Time: 4.23.25

2:34 pm



181 US Hwy 46
Mine Hill, NJ 07803
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Hopatcong Borough Schools
2 Windsor Ave, Hopatcong, NJ, 07843

Performed For:

Hopatcong Borough Schools
Mr. Gregory Smyth
2 Windsor Ave, PO Box 1029, Hopatcong, NJ, 07843

Prepared By:

LEW Environmental Services, LLC.
181 US Hwy 46
Mine Hill, NJ 07803

Phone (908) 654-8068
Fax (908) 654-8069
Website <http://www.LEWCorp.com>


Inspection Date: 04/04/2025
Project Number: 2735

Contact Information

Education Agency

Client Contact:	Mr. Gregory Smyth
Client Name:	Hopatcong Borough Schools
Street Address	2 Windsor Ave, PO Box 1029 , Hopatcong, NJ, 07843
Phone Number:	(973) 770-88403

Sampler(s)

Site Assessor(s):	Marvin Ayumbi, Erick Ulloa
Signature:	
Date:	May 13, 2025

Firm

Organization:	LEW Environmental Services, LLC.
Certification #:	NJDCA 00015 E
Street:	181 US Hwy 46
City, State & Zip:	Mine Hill, NJ 07803
Phone Number:	908-654-8068
Web Address:	http://www.lewcorp.com

Laboratory

Organization:	Environmental Hazard Services, LLC
Street:	7469 Whitepine Road
City, State & Zip:	Richmond, VA 23237
NJDEP Certification #	VA008
Phone Number:	800-347-4010

Introduction

LEW Environmental Services, LLC. was contracted by Hopatcong Borough Schools to test for the presence of lead in drinking water in five facilities in the district.

Sampling Methodology

LEW Environmental Services, LLC. followed NJAC 6A:26. Full details on sampling practices can be found in Districts Sampling Plan.

All samples were collected in 250mL wide mouth plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not, nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours. If second draw samples were collected, they were collecting following a flushing protocol outlined in the District's Sampling Plan.